

Testing

Periodic electrical checks must be performed on all electrical protection equipment. See the table below:

Type of Equipment	When to Test
Rubber insulating line hose	Upon sign that insulating value is debatable and after repair.
Rubber insulating covers	Upon sign that insulating value is doubtful and after repair.
Rubber insulating blankets	Before first issue and every 12 months thereafter ¹ upon indication that insulating value is debatable; and after restoration.
Rubber insulating gloves	Before the first issue and every six months thereafter ¹ upon a sign that insulating value is suspect; after repair; and after use without protectors.
Rubber insulating sleeves	Before the first issue and every 12 months thereafter ¹ upon indication that insulating value is suspect, and after repair.